



**Certification and Testing Service, Inc.**

41755 Elm Street, Suite 202  
Murrieta, CA 92562  
Tel: 951-894-6079 Fax: 951-894-6083

www.CleanroomTestCertification.com

## ***CERTIFICATE OF CERTIFICATION***

COMPANY	<u>Konicom, Inc.</u>	TEST DATE:	<u>October 13, 2017</u>
ADDRESS	<u>1819 J Street</u>	DUE DATE:	<u>October 2018</u>
	<u>Sacramento, CA 95811</u>	REQUESTOR:	<u>Bryan Wu</u>
CLEANROOM/S TESTED	<u>Production CER</u>		


### AIRBORNE PARTICULATE CLEANLINESS CLASS TESTING RESULTS :

	<u>CLASS MET</u>	<u>MICRON</u>	<u>CONDITION</u>
ROOM: <u>PRODUCTION</u>	<u>ISO CLASS 5</u>	<u>0.5, 1.0 &amp; 5.0</u>	<u>At-Rest</u>

TEST EQUIPMENT: Climet Model 750T

CALIBRATION DUE DATE: November 30, 2017

**CERTIFIED PER ISO 14644-1:1999(E) CLEANLINESS CLASSIFICATION**

 Date: 11-16-2017

Signature of Approval

CTS Certification and Testing Service, Inc.